

DOCKET NO. 18-0150-1601 - ADOPTION OF PENDING RULE

Substantive changes have been made to the pending rule.
Italicized red text that is double underscored is new text that has been added to the pending rule.

Only those sections or subsections that have changed from the original proposed text are printed in this Bulletin following this notice.

The text of the proposed rule was published in the Idaho Administrative Bulletin, Vol. 16-9, pages 143-147.

This rule has been adopted as a pending rule by the Agency and is now awaiting review and final approval by the 2017 Idaho State Legislature.

THE FOLLOWING IS THE TEXT OF THE AMENDED PENDING RULE FOR
DOCKET NO. 18-0150-1601

[Codified Section 020 is being moved to Proposed Section 019 and new text for Section 020 is being introduced.]

~~019. (RESERVED)~~

~~02019. DEFINITION OF CODE OFFICIAL, SECTION 202, INTERNATIONAL FIRE CODE.~~

~~01. Fire Code Official. Add "or as appropriate the Idaho State Fire Marshal" to the end of the definition for FIRE CODE OFFICIAL in Section 202 of the International Fire Code. (3-20-14)()~~

~~02. Driveway. Add "DRIVEWAY. A vehicular ingress and egress route that serves no more than five (5) single family dwellings, not including accessory structures." ()~~

~~03. Fire Station. Add "FIRE STATION, A building, or portion of a building that provides, at a minimum, all weather protection for fire apparatus. Temperatures inside the building used for this purpose must be maintained at above thirty-two (32) degrees Fahrenheit." ()~~

~~020. SKY LANTERNS, SECTION 308.1.6.3, INTERNATIONAL FIRE CODE.~~

~~01. Untethered Sky lanterns. To section 308.1.6.3 delete the sentence: "A person shall not release or cause to be released an untethered sky lantern." ()~~

~~02. Sky lantern permit. To section 308.1.6.3 add the following: "A person shall not release or cause to be released a sky lantern, tethered or untethered without obtaining a permit, if required by the fire code or jurisdiction. When, in the opinion of the fire code official, the release of sky lanterns, tethered or untethered, constitutes a danger to persons or property, based on the current weather conditions, knowledge of topography, vegetation, or any other reasonable factor, is authorized to require additional safeguards prior to the release of sky lanterns. The fire code official may suspend, revoke, postpone, or prohibit the release of any sky lantern at any time." ()~~