

THE FOLLOWING IS THE PROPOSED TEXT OF DOCKET NO. 18-0149-1801
(Only Those Sections With Amendments Are Shown.)

011. POWERS AND DUTIES OF THE STATE FIRE MARSHAL.

In addition to the powers and duties prescribed in this rule, the State Fire Marshal shall: (7-1-93)

01. Assistants, Inspectors and Other Employees. Appoint an adequate number of assistants, inspectors and other employees that may be necessary to carry out the provisions of this rule, prescribe their duties, and fix their compensation within the amount appropriated. (7-1-93)

02. Licensing Procedures. Establish procedures for licensing of fire protection sprinkler contractors and fitters, set forth the form and content of applications, and investigate and examine all applicants as to their qualifications and fitness for such licensing. (7-1-93)

03. Records. Keep records of all licenses issued, suspended or revoked. (1-1-94)

04. Suspension or Revocation of License. Suspend or revoke any license for any cause prescribed by this rule, and refuse to grant any license for any cause which would be grounds for revocation or suspension. (7-1-93)

05. Examinations. Prepare, administer, and grade such applicable examinations and tests for applicants as may be required for the purposes of this rule, and determine the score that shall be deemed a passing score. (7-1-93)

06. Fees. Collect fees, including applications, testing, licensing, renewals, and duplication fees from the applicants, and license holders for the purpose of administering and funding this rule. (7-1-93)

~~**07. Advisory Board.** Appoint an advisory board consisting of six (6) members whose duties shall be to advise and counsel the State Fire Marshal on matters contained in this rule. One (1) or more representatives from each of the following professions or occupations shall be appointed to the board. (1-1-94)~~

~~**a. Architect.** (1-1-94)~~

~~**b. Mechanical Engineer.** (1-1-94)~~

~~**c. Fire Service Official.** (1-1-94)~~

~~**d. General Contractor.** (1-1-94)~~

~~**e. Licensed Fire Sprinkler Contractor—Two (2).** (1-1-94)~~

~~**f. The terms of the members of the board first appointed shall expire as follows: three (3) members two (2) years later, three (3) members three (3) years later. Thereafter, appointments shall be for three (3) years. At its first meeting of every calendar year the board shall elect a president from its members, and a secretary who may or may not be a member of the board. Members of the board shall serve without compensation. The staff of the office of the State Fire Marshal shall provide such assistance as the board may require. (1-1-94)**~~

(BREAK IN CONTINUITY OF SECTIONS)

020. SERVICE EVIDENCE.

01. Submission of Plans. Where automatic fire sprinkler systems are installed, the installer shall complete the contractor's material and test certificates NFPA 1~~23~~ 1-10.1. All systems must be under the supervision of a contractor or a R.M.E. These persons shall cause proper tests and inspections to be made at prescribed intervals and must have general charge of all alterations and additions to the systems under their supervision. (7-1-93)()

02. Conformance to Standards. A service tag conforming to the requirements of this chapter shall be attached to all systems. (7-1-93)

021. DESIGN REQUIREMENTS.

01. Submission of Plans. Detailed plans in accordance with applicable NFPA standards must be submitted by a licensed contractor for approval to the local fire department and to the State Fire Marshal. (7-1-93)

02. Conformance to Standards. The specifications must state that the installation will conform to the applicable standards listed in this rule and be approved by the local fire department and the State Fire Marshal. (7-1-93)

03. Tests. The specifications must include the specific tests required to meet the standards for approval of the local fire department and the State Fire Marshal. (7-1-93)

04. Scale. Plans must be drawn to an indicated scale or be suitably dimensioned, and must be made so that they can be easily reproduced. (7-1-93)

05. Detail. Plans must contain sufficient detail to evaluate the effectiveness of the system. (7-1-93)

06. Prior Approval of Plans. Plans must be submitted to the State Fire Marshal and the local fire department and approved, before work starts. Work may start prior to final plans submitted based on conceptual drawings if approved by the local fire department and the State Fire Marshal. A plans review fee of two dollars (\$2) per sprinkler head up to one thousand (1000) heads per fire protection sprinkler system (maximum two thousand dollars (\$2,000)) or one hundred dollars (\$100) per fire protection sprinkler system if less than fifty (50) sprinkler heads ~~or one percent (1%) of the total bid price (whichever is larger) up to the maximum of two thousand dollars (\$2,000) or the minimum of one hundred dollars (\$100).~~ The applicable fee must accompany the plans sent to the State Fire Marshal. Two (2) sprinkler heads on an arm-over will be considered as one (1) sprinkler head for fee purposes. (7-1-93)()

07. Corrected Plans. Where field conditions necessitate any substantial change from the approved plan, the corrected plan showing the system as installed must be submitted to the local fire department and the State Fire Marshal for approval. (7-1-93)

08. Exemption. A City or County may request, and the State Fire Marshal may grant, an exemption from the requirements of this Section that plans be submitted to the State Fire Marshal for review and approval. A request for exemption shall be made in writing signed by the Fire Chief, his designated representative or elected local official and shall set forth the reasons for the request. If the State Fire Marshal determines the request is justified, the requesting party will be provided a written notice of exemption. The exemption will continue until terminated by the State Fire Marshal. Any such exemption shall not apply to plans or inspections relating to structures owned, leased or controlled by the state or any state agency. (4-5-00)